

## 排ガス測定結果

日付	2020.8	2021.3	2021.9	2022.3					
ばいじん (g/m <sup>3</sup> N)	<0.0051	<0.0049	<0.0040						
硫黄酸化物 (m <sup>3</sup> /h)	<0.0078	<0.0015	<0.0065						
窒素酸化物 (ppm)	81	100	72						
HCL (mg/m <sup>3</sup> N)	<10	10	22						
ダイオキシン類 (ng-TEQ/m <sup>3</sup> N)	0.16	-	0.8						
水銀 (ug/Nm <sup>3</sup> )	1.2	1.6	1						
CO値 (ppm)	58	29	5						
O <sub>2</sub> (%)	12.2	12.3	9.8						